

令和 4年 3月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	原水水質試験結果 (沈砂池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	10.5	5.9	0.8	7.47	18.6	22.1	34.0	4.7	0.03	<0.02	
2	晴	8.5	6.0	0.8	7.38							
3	晴	9.2	6.4	0.5	7.31							
4	晴	7.0	6.7	0.5	7.34							
5	晴	12.7	6.9	0.5	7.30							
6	晴	8.4	7.2	0.6	7.28							
7	晴	4.9	6.9	0.5	7.30							
8	晴	8.0	6.8	0.5	7.33							
9	曇	9.5	7.1	0.5	7.31							
10	晴	9.9	6.8	0.7	7.27							
11	晴	11.0	6.9	0.5	7.24							
12	晴	15.3	7.2	0.5	7.22							
13	晴	18.5	7.5	0.6	7.24							
14	晴	15.1	8.0	0.5	7.25							
15	曇	7.0	8.7	0.5	7.28	14.8	17.5	30.0	3.1	0.04	<0.02	
16	晴	14.6	9.4	0.5	7.26							
17	晴	14.0	9.9	0.6	7.25							
18	曇	12.0	10.3	0.6	7.24							
19	晴	13.2	10.4	0.6	7.26							
20	晴	10.0	10.1	0.5	7.19							
21	曇	9.3	10.1	0.7	7.23							
22	雨	6.1	9.8	0.8	7.25							
23	晴	7.5	9.9	0.7	7.28							
24	晴	11.0	9.5	0.6	7.21							
25	晴	13.5	9.5	0.5	7.30							
26	曇	14.3	9.4	0.6	7.24							
27	晴	15.6	10.1	11.8	7.13							
28	晴	13.9	10.2	3.0	6.92							
29	曇	11.7	11.1	1.8	7.03							
30	晴	16.1	11.5	1.4	7.14							
31	曇	16.0	11.1	0.8	7.17							
平均		11.4	8.6	1.1	7.25	16.7	19.8	32	3.9	0.04	<0.02	
最高		18.5	11.5	11.8	7.47	18.6	22.1	34	4.7	0.04	<0.02	
最低		4.9	5.9	0.5	6.92	14.8	17.5	30	3.1	0.03	<0.02	

令和 4年 3月分

湖西工業用水道水質試験結果報告書 (梅田浄水場)

採水時間 9:00

日	天候	気温 ℃	浄水 水質試験結果 (配水池)									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発 残留物 mg/L	塩化物 イオン mg/L	鉄 mg/L	マン ガン mg/L	
1	晴	10.5	6.1	0.7	7.48	18.5	21.8	38.0	4.6	<0.03	<0.02	
2	晴	8.5	6.1	0.7	7.40							
3	晴	9.2	6.4	0.6	7.41							
4	晴	7.0	6.5	0.5	7.34							
5	晴	12.7	6.8	0.5	7.31							
6	晴	8.4	7.1	0.5	7.28							
7	晴	4.9	7.0	0.4	7.31							
8	晴	8.0	6.8	0.4	7.31							
9	曇	9.5	7.0	0.4	7.30							
10	晴	9.9	7.1	0.4	7.25							
11	晴	11.0	7.2	0.5	7.30							
12	晴	15.3	7.5	0.5	7.30							
13	晴	18.5	7.9	0.5	7.29							
14	晴	15.1	8.4	0.5	7.28							
15	曇	7.0	9.1	0.5	7.28	14.6	16.7	30.0	2.9	0.04	<0.02	
16	晴	14.6	9.3	0.4	7.31							
17	晴	14.0	9.9	0.5	7.25							
18	曇	12.0	10.4	0.5	7.30							
19	晴	13.2	10.5	0.5	7.26							
20	晴	10.0	10.4	0.5	7.32							
21	曇	9.3	10.3	0.5	7.30							
22	雨	6.1	10.2	0.6	7.31							
23	晴	7.5	9.9	0.6	7.30							
24	晴	11.0	9.9	0.7	7.29							
25	晴	13.5	9.9	0.5	7.31							
26	曇	14.3	10.1	0.5	7.34							
27	晴	15.6	10.2	0.5	7.29							
28	晴	13.9	10.5	0.7	6.95							
29	曇	11.7	10.8	1.5	6.93							
30	晴	16.1	11.2	1.4	7.01							
31	曇	16.0	11.8	1.1	7.09							
平均		11.4	8.8	0.6	7.27	16.6	19.2	34	3.8	0.03	<0.02	
最高		18.5	11.8	1.5	7.48	18.5	21.8	38	4.6	0.04	<0.02	
最低		4.9	6.1	0.4	6.93	14.6	16.7	30	2.9	<0.03	<0.02	