

令和7年3月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 （ 配 水 : 配 水 池 ）									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	12.2	14.3	0.00	7.5							
2	晴	14.0	14.2	0.00	7.4							
3	雨	11.0	14.2	0.00	7.4	50.1	75.9	107	1.5	<0.02	<0.02	
4	曇	6.5	13.9	0.00	7.4							
5	雨	9.0	13.8	0.00	7.5							
6	曇	12.0	13.9	0.00	7.4							
7	晴	8.3	13.8	0.00	7.5							
8	曇	6.1	13.7	0.00	7.5							
9	晴	8.3	13.7	0.00	7.6							
10	晴	10.1	13.7	0.00	7.8							
11	曇	11.8	13.8	0.00	7.6							
12	曇	14.1	13.8	0.00	7.6							
13	曇	14.9	13.9	0.00	7.5							
14	晴	14.8	13.9	0.00	7.5							
15	曇	11.0	13.9	0.00	7.6							
16	雨	7.3	13.7	0.00	7.4							
17	晴	11.4	13.7	0.00	7.4	50.8	76.1	116	1.6	<0.02	<0.02	
18	晴	10.0	13.8	0.00	7.5							
19	曇	8.4	13.7	0.00	7.4							
20	晴	8.5	13.7	0.00	7.5							
21	晴	10.0	13.8	0.00	7.6							
22	晴	17.0	13.9	0.00	7.6							
23	晴	17.0	14.0	0.00	7.6							
24	曇	16.4	14.0	0.00	7.4							
25	晴	15.8	14.0	0.00	7.6							
26	晴	22.8	14.2	0.00	7.5							
27	晴	18.8	14.2	0.00	7.4							
28	晴	20.6	14.3	0.00	7.5							
29	晴	13.0	14.2	0.00	7.6							
30	雨	11.5	14.2	0.00	7.5							
31	曇	9.7	14.0	0.00	7.4							
平均		12.3	13.9	0.00	7.5	50.5	76.0	112	1.6	<0.02	<0.02	
最高		22.8	14.3	0.00	7.8	50.8	76.1	116	1.6	<0.02	<0.02	
最低		6.1	13.7	0.00	7.4	50.1	75.9	107	1.5	<0.02	<0.02	