

令和7年4月

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 （ 配 水 : 配 水 池 ）									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	9.2	13.8	0.00	7.9							
2	曇	16.0	13.9	0.00	7.4							
3	雨	11.1	13.9	0.00	7.6							
4	晴	13.6	13.9	0.00	7.4							
5	晴	12.1	13.9	0.00	7.6							
6	雨	13.0	14.0	0.00	7.8							
7	晴	14.9	14.0	0.00	7.3	50.6	79.7	129	1.5	<0.02	<0.02	
8	晴	15.7	14.0	0.00	7.8							
9	晴	17.5	14.2	0.00	7.5							
10	晴	18.0	14.2	0.00	7.6							
11	曇	17.4	14.3	0.00	7.5							
12	晴	17.7	14.3	0.00	7.6							
13	雨	13.7	14.3	0.00	7.5							
14	晴	18.7	14.2	0.00	7.4							
15	曇	16.4	14.3	0.00	7.6							
16	晴	13.7	14.3	0.00	7.5							
17	晴	17.0	14.3	0.00	7.5							
18	曇	20.0	14.4	0.00	7.5							
19	晴	21.5	14.6	0.00	7.5							
20	曇	22.0	14.7	0.00	7.5							
21	晴	22.0	14.6	0.00	7.9	48.7	77.4	113	1.5	<0.02	<0.02	
22	曇	20.5	14.7	0.00	7.5							
23	雨	17.4	14.7	0.00	7.6							
24	雨	20.3	14.7	0.00	7.3							
25	曇	19.4	14.7	0.00	7.4							
26	曇	18.8	14.7	0.00	7.5							
27	晴	18.2	14.8	0.00	7.5							
28	曇	21.6	14.8	0.00	7.5							
29	晴	16.7	14.8	0.00	7.5							
30	晴	18.3	14.9	0.00	7.5							
31												
平均		17.1	14.4	0.00	7.5	49.7	78.6	121	1.5	<0.02	<0.02	
最高		22.0	14.9	0.00	7.9	50.6	79.7	129	1.5	<0.02	<0.02	
最低		9.2	13.8	0.00	7.3	48.7	77.4	113	1.5	<0.02	<0.02	